

VOC Content Test Certificate

Wednesday 22nd December 2021

Supplier: SELLEYS Pty Ltd (1 Gow Street, PADSTOW, NSW, 2211, AUSTRALIA).

Sample Description: Selleys Liquid Nails VBS Rapid Kit

Date Tested: December 2021 (Tested by FORAY Laboratories – NATA Accreditation 1231)


Test Method: ASTM D3960-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

| | |
|---|--|
| <p align="center">Specification</p> <p align="center">Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B</p> | <p align="center">Selleys Liquid Nails VBS Rapid Kit</p> |
| <p align="center">Acoustic Sealants, Waterproofing Membranes and Sealant limit: 250 grams per litre</p> | <p align="center">151 grams per Litre as VOC content per material</p> |
| <p align="center"><i>We hereby certify that Selleys Liquid Nails VBS Rapid Kit product is below the VOC Content limits of chosen categories specified by Green Building Council of Australia, Green Star Design & As Built, and Green Star Interiors</i></p> | |



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chem. Eng.)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Consultant

V2112041